

SECTION IX

AIR CONDITIONING, REFRIGERATION & APPLIANCE TRANSFORMERS

GROUP B

PRIMARY VOLTS

NOMINAL SECONDARY VOLTS

Tap Conn.	50 Hz	60 Hz	50 Hz	60 Hz
High	230-260	253-283	105	115
Medium	210-239	230-260		
Low	189-217	208-236		



RECEPTACLE

Catalog No.	VA Rating	Output Amps	Approx. Dimensions (Inches)			Approx. Ship Wt. (lbs.)	Connections
			Height	Width	Depth		
T-1-60808 ^①	350	3.04	9.16	3.89	3.67	8	6' primary cord and secondary receptacle
T-1-60810 ^①	550	4.78	9.68	4.75	4.51	10	6' primary cord and secondary receptacle
T-1-60812 ^①	750	6.51	9.68	4.75	4.51	11	6' primary cord and secondary receptacle
T-1-60814 ^①	1000	8.70	9.68	4.75	4.51	14	6' primary cord and secondary receptacle
T-1-60816 ^①	1500	13.04	10.50	5.50	5.13	21	6' primary cord and secondary receptacle

GROUP C

PRIMARY VOLTS — 200/220/240

SECONDARY VOLTS — 115, 50/60 Hz



RECEPTACLE

Catalog No.	VA Rating	Output Amps	Approx. Dimensions (Inches)			Approx. Ship Wt. (lbs.)	Connections
			Height	Width	Depth		
T-1-60830 ^①	200	1.74	9.16	3.89	3.67	6	6' primary cord and secondary receptacle
T-1-60831 ^①	300	2.61	9.16	3.89	3.67	6	6' primary cord and secondary receptacle
T-1-60832 ^①	400	3.48	9.16	3.89	3.67	8	6' primary cord and secondary receptacle
T-1-60833 ^①	500	4.35	9.68	4.75	4.51	10	6' primary cord and secondary receptacle
T-1-60834 ^①	1000	8.70	9.68	4.75	4.51	14	6' primary cord and secondary receptacle
T-1-60835 ^①	2000	17.40	11.50	7.81	7.13	27	6' primary cord and 2 secondary receptacle

GROUP D

PRIMARY VOLTS — 230

SECONDARY VOLTS — 115, 50/60 Hz



RECEPTACLE

Catalog No.	VA Rating	Output Amps	Approx. Dimensions (Inches)			Approx. Ship Wt. (lbs.)	Connections
			Height	Width	Depth		
T-1-60828 ^②	85	0.74	9.16	3.89	3.67	4	6' primary cord and secondary receptacle
T-1-60829 ^②	125	1.09	9.16	3.89	3.67	4	6' primary cord and secondary receptacle
T-1-60837 ^②	250	2.17	9.16	3.89	3.67	6	6' primary cord and secondary receptacle
T-1-60838 ^②	500	4.35	9.68	4.75	4.51	10	6' primary cord and secondary receptacle
T-1-60839 ^②	750	6.51	9.68	4.75	4.51	12	6' primary cord and secondary receptacle
T-1-60840 ^②	1500	13.04	10.50	5.50	5.13	21	6' primary cord and secondary receptacle

^① Electrical Tap Connections — Do not exceed +5% of nominal voltage without changing taps.

^② No Taps — Do not exceed +5% of nominal voltage.