

Product change information

PCN no.:	ACM130015	Date:	11/21/2016
----------	-----------	-------	------------

Order no.	Designation	As of article revision
2320212	QUINT-UPS/24DC/24DC/5	06
2320225	QUINT-UPS/24DC/24DC/10	06
2320238	QUINT-UPS/24DC/24DC/20	06
2320241	QUINT-UPS/24DC/24DC/40	06


Description of the change

Product fit
 Product form
 Product function


DNV-GL and ABS approval granted, remote shutdown and Modbus configuration added

- 1.) DNV-GL and ABS: approvals are granted.
- 2.) Remote shutdown: R2 activation is indicated by a green flashing LED (POWER IN OK). PC mode includes PC shutdown per remote control. Temporary and permanent operating modes are unchanged.
- 3.) Modbus configuration: Modbus address and baud rate are adjustable. Configuration up to V/C:04 cannot be applied from a stick or file. V/C:06 devices are supported by UPS-CONF as of v2.2.7.3.

Previous production status



New production status



Effects of the product change

Stock / delivery status

Existing stock can still be used: yes no

Expected first delivery of the changed product(s):

Can already be delivered